

C/67

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/240

Dated:- 17.5.2024

To,

The Manager
M/S Leo Guest House,
3357, Gali Hari Mandir,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o Leo Guest House located at 3357, Gali Hari Mandir, Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2024012500858 dated 16.04.24, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 13/05/2024 in the presence of **Manager** and following shortcomings were observed: -

1. Hose reel provided but found nonfunctional .
2. Pump found removed.

Hence, The case is rejected with a request to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police(lic), 1st floor, Defence Colony Police Station, New Delhi.