

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/WZ/2024/241

Dated:- 16/05/2024

To,

The Principal,
M. C. Pratibha School (Girls),
Jwalapuri A-1, New Delhi-110087.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of M.C. Pratibha School (Girls), located Jwalapuri A-1, New Delhi-110087.

Sir,

Please refer to your Form 'J' dated nil on the subject cited above. In this connection, it is to inform you that the above said school building was re-inspected by the officer concerned of this department on 09/05/2024 in the presence of Meenakshi Trehan (Principal). During inspection, it has been observed that the school building is comprised of 01 blocks - Ground + 01 upper floor, 01 block - Ground + 02 upper floors & 02 blocks - Ground. However, the following shortcoming has been observed:-

1. First Aid Hose Reel found non-functional.
2. Terrace pump of 450 lpm capacity found non-functional.
3. Overhead water storage tank 10,000 ltrs. Capacity found reduced to 5000 ltrs.
4. Electrical meters/panels found underneath the staircases, same shall be shifted on another safe place.

In view of the above shortcomings, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

(Atul Garg)
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.