

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/FH/2024/SZ/268
To

Dated: 17/05/2024

The Addl. Commissioner of Police,
Lic/Unit, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s **New Vasu Garden By Sat Kartar Caterers** at
Chattarpur Main Road, Chandanhulla Village, New Delhi-110074

Sir,

This is in reference with **MHA Portal ID 2024041605204 Dated 17.04.2024** on the subject cited above. In this connection, it is to inform you that the premise has been inspected by officer concerned of this department on 15.05.2024 in the presence of Mr. Gurjeet Singh of the Farm House. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First Aid hose reel provided but found nonfunctional.
2. Internal hydrant provided but found nonfunctional.
3. Fire fighting pumps provide but found not working.
4. Terrace tank could not be checked due to not accessibility of tank.
5. The Exit Signage found removed.

The same observations has already been issued and communicated earlier by this department vide letter of even no 177 dated 09/04/2024.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

ATUL GARG