



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

C-19

Dated: 16/05/2024

No. F6/DFS/MS/WZ/2024/ 244  
To,

The Principal,  
Nigam Utkrist Vidyalaya,  
C-7, Suraj Kunj, Keshav Puram,  
New Delhi- 110035.

**Sub: - Inspection report in r/o Nigam Utkrist Vidyalaya located at C-7, Suraj Kuni, Keshavpuram, New Delhi- 110035.**

Sir,

This is in reference to your letter no. Nil dated 01/05/2024 received via outdoor diary no. 1297 dated 02/05/2024 on the subject cited above. In this connection, it is to inform you that the above said school building was re-inspected by the officer concerned of this department on 10/05/2024 in the presence of Smt. Sanju Agarwal (Principal) to verify the compliance of shortcomings communicated vide this department letter No. F6/DFS/MS/School/WZ/2023/254 dated 17/05/2023.

The status of shortcoming is as under:-

Sr. No	Shortcomings	Status
1.	First aid hose reels are provided but not functional.	Not Rectified
2.	Terrace pump of 450 lpm is provided but not on auto mode.	Not Rectified
3.	Overhead water storage tank of capacity of 10,000 ltrs is provided but not exclusively for fire fighting purpose.	Not Rectified

In addition to the above mentioned shortcoming it is to inform you that electrical panel and electric meter installed under the staircase have to be removed to a safer place.

In view of the above shortcomings, the request for issuance of Fire Safety Certificate can't be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for further necessary action in this regard.

Yours faithfully,

(Atul Garg)  
Director

Ph. 011-23414000

15/5/2024

Copy to:-

1. The Director, Directorate of Education, Old Secretariat, Delhi.