



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

C-20
16/05/2024

No. F.6/DFS/MS/2024/WZI/100

Dated 16/05/2024

To

Ms. Ruchika Aggarwal,
FD- 3, Pitampura,
Delhi- 110088.

Sub.: - Regarding issuance of fire safety certificate in r/o Coaching Centre located at Plot No. 03, FD-Block, Pitampura, Delhi- 110088.

Sir,

This is in reference to your letter No. nil dated nil received through outdoor diary No. 927 dated 22.04.2024, on the subject cited above. In this connection, it is to inform you that the above said coaching centre was inspected by the officer concerned of this department on 01.05.2024 in the presence of Sh. Akhilesh, to check the fire safety and means of escape measures.

During the course of inspection, it was observed that the building is comprised of basement, stilt, ground plus three upper floors. Fire safety arrangements such as fire extinguishers, sprinkler system, water tank, fire pumps etc. found provided. However, following shortcomings were observed: -

1. Fire & Smoke Check Door are not provided in staircase lobbies.
2. Width of the corridor is less than required width of 1.5 mts.
3. Ventilation in basement and upper floors is not provided.
4. Fire pumps were not on auto mode.
5. Openable window shall be provided at each floor.
6. Exit signages are not provided.

In view of above shortcomings, fire safety certificate is not considered and rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department. The occupancy of the building/premises in absence of requisite fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully

(Atul Garg)
Director

Copy to: -

1. The Executive Engineer (Bldg.) HQ, MCD, 9th Floor, Civic Centre, Minto Road, New Delhi- 110002.