

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2024/SZ/ 282
To

Dated: 24/05/2024

The Authorized Signatory,
For MP Power Madhya Pradesh,
Plot No 239, Okhla Industrial Estate,
Phase -III, New Delhi 110020

Sub.:- Regarding grant of Fire Safety Certificate in r/o M/s Industrial building at Plot No 239, Okhla Industrial Estate, Phase -III, New Delhi

Sir,

This has reference to with letter no nil dated 26/04/2024 received through outdoor diary no 1132 dated 26/04/2024 on the subject above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.05.2024 to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 Fire check door closing device found removed & sealing of shaft not sealed at some places.
- 2 First aid hose reel provided but found nonfunctional.
- 3 Internal & yard hydrant provided but found nonfunctional.
- 4 Fire fighting pumps are not on auto mode.
- 5 Exit signage found removed at some places.

The same observations has already been issued and communicated earlier by this department vide letter of even no 193 dated 16/04/2024

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer, Bldg Department, Central zone Jai Vihar Lajpat Nagar, New Delhi 110024