



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/ Mercantile /NDZ/2024/270

Dated: 17/05/2024

To,

The Executive Engineer (Bldg.) HQ,  
Municipal Corporation of Delhi,  
419, Udyog Vihar, Patparganj Industrial Area,  
Delhi – 110092.

**Sub: - Regarding grant of Fire Safety Certificate in r/o Plot No. C- 65, Preet Vihar Delhi - 110092.**

Sir,

This has a reference to your MCD Portal ID no. 10095390 dated 06/05/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by a team of officers of this department on 14/05/2024 in the presence of Mr. Joginder Sharma (Owner). Mr. Rajender Kumar (JE / Bldg.), MCD was also present for joint inspection. During inspection it was observed that mercantile building is comprised of basement, Stilt, Ground plus two upper floors. Following shortcomings were observed during time of inspection.

1. The work for provision of Fire Check Doors is in progress.
2. The work for Segregation of staircases at stilt level is in progress.
3. In Basement & Stilt Floor, water curtain for car lift not provided.
4. The work for Smoke Management System for basement & upper floors is in progress.
5. The work for provision of MOEFA is in progress.
6. The work for provision of pressurization is in progress.
7. The work for provision of Inspection Ladder for Overhead water storage tank is in progress.

In view of above, the application for issuance for Fire Safety Certificate is not considered at this stage.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

(u)