



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आजादी का
अमृत महोत्सव

No. F6 /DFS/MS/School/NDZ/2024/ 253

Dated: 16/05/2024

To,

The Manager
Purvanchal Public School,
Chilla, Mayur Vihar Phase-1,
Delhi-110091.

Sub: - Regarding grant of Fire Safety Certificate in r/o Purvanchal Public School, Chilla, Mayur Vihar Phase-1, Delhi-110091.

Sir,

This has a reference to your outdoor dairy no.322 dated 30/04/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 07/05/2024 in the presence of Mrs. Poonam Saini (Principal) and observed that building comprised of ground plus two upper floors only.

Following shortcomings were observed during time of inspection:

1. Fire Extinguisher not provided.
2. First-Aid-Hose Reel provided but not functionable.
3. Fire pump of capacity 450 LPM not provided.
4. Overhead tank of 5,000 liters capacity is provided against the requirement of 10,000 liters
5. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The Manager, Purvanchal Public School located at Chilla, Mayur Vihar Phase -1, Delhi-110091.