



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/School/NDZ/2024/ 248

Dated: 16/05/2024

To,

The Principal,  
Raja Ravi Verma Sarvodaya Kanya Vidyalaya  
B - Block Nand Nagri, Delhi - 110093.

**Sub: - Regarding grant of Fire Safety Certificate in r/o Raja Ravi Verma Sarvodaya Kanya Vidyalaya located at B - Block Nand Nagri, Delhi – 110093.**

Sir,

This has a reference to your email dated 25/04/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 07/05/2024 in the presence of Mrs. Vineeta Kashyap (Vive - Principal) and observed that building comprised of ground plus three upper floors. (New Building)

**Following shortcomings were observed during time of inspection:**

1. First-Aid-Hose Reel provided but not functional.
2. Fire pump of 450 LPM provided but not functional.
3. Overhead tank capacity 10,000 liters not provided.
4. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, Raja Ravi Verma Sarvodaya Kanya Vidyalaya located at B - Block Nand Nagri, Delhi – 110093.