



Dated: 20/05/2024

No. F6/DFS/MS/BNQT/NDZ/2024/ 278

To,

The Owner,  
Royal Imperial Feast Community Hall OCF Pocket,  
Mandawali Fazalpur, Opposite Bathla CGHS,  
Patparganj Extension, Delhi - 110092.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Royal Imperial Feast Community Hall OCF Pocket, Mandawali Fazalpur, Opposite Bathla CGHS, Patparganj Extension, Delhi - 110092.**

Sir,

This has a reference to your MHA application no. 2024041605295 dated 18/04/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 07/05/2024 in the presence of Mr. Anoop Minoch (Owner) and observed that building comprised of basement, ground plus one upper floor.

**Following shortcomings were observed during time of inspection:**

1. First-Aid-Hose Reel provided but not functional.
2. Automatic Sprinkler system provided but not functional.
3. Internal Hydrants provided but not functional.
4. Fire pump of 900 LPM provided but not functional.
5. Underground and overhead water storage tank capacity 10,000 liters and 12,500 liters respectively not provided.
6. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

01/DELHI FIRE SERVICE

Copy to:-

1. The Deputy Commissioner (Licensing), 1<sup>st</sup> Floor, Police Station Defence Colony, New Delhi  
Online application ID - 2024041605295 dated 18/04/2024.
2. The Manger, Royal Imperial Feast Community Hall located at OCF Pocket, Mandawali Fazalpur, Opposite Bathla CGHS, Patparganj Extension, Delhi - 110092.