

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2024/ 261

Dated: 21/05/2024

To

The Principal,
Sanatan Dharam Public School,
Road No. 10, East Punjabi Bagh,
New Delhi -110026.

Subject: Regarding renewal of Fire safety Certificate in respect of M/s. Sanatan Dharam Public School, Road No. 10, East Punjabi Bagh, New Delhi-110026.

Sir,

Please refer to your letter no. SDPS/10557/2024 dated 10/04/2024 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 14/05/2024 in the presence of Sh. Surender Kaushik (Care Taker) to see the functioning of fire safety equipments provided in the building.

During inspection it has been observed that the building is comprised of Ground + 02 upper floors. Fire Safety arrangements such as Fire Extinguisher, P.A System, Internal Hydrant, First-Aid Hose reel, Pumping arrangements, Over Head Tank, etc are provided. However, the following shortcomings were observed:-

1. First-Aid Hose Reels are provided found damage at some places.
2. Terrace level pump capacity of 450lpm & 180lpm provided but not on auto mode.
3. Exit signages found removed.

In view of above Shortcomings the application for renewal of Fire safety Certificate is cannot consider at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier. Statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Copy To: -

1. The Director, Directorate of Education, old secretariat, Delhi.