



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आजादी का
अमृत महोत्सव
c/02

No.F6/DFS/MS/School/SZ/2024/ 262

Dated: 21/05/2024

To

The Principal,
Shivalik Public School,
D-8A, Mohan Baba Nagar,
Tajpur Road, Badarpur, New Delhi-44.

Sub:- Regarding issuance of Fire Safety Certificate in r/o **Shivalik Public School** located at **D-8A, Mohan Baba Nagar, Tajpur Road, Badarpur, New Delhi-44.**

Sir,

With reference to your letter no. SPS/01/24-25 dated 17.04.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 10.05.2024 in the presence of Mrs. Sunita (Principal) and it was observed that the building is comprised of Ground + 04 upper floors. During the inspection following shortcomings were observed:-

1. 2 nos. of staircases 1.50 meters width each not provided in the building.
2. 10 nos. of fire extinguishers not provided.
3. First aid hose reels not provided at each floor.
4. Fire pump of 450 LPM with head 40 m not provided.
5. Terrace water tank of 10,000 liters not provided (exclusively for firefighting).
6. Exit signages not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

14.5.24

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Executive Engineer (Building), MCD, Jal Vihar, Lajpat Nagar, New Delhi-24:- To verify the height of the building under intimation to this department.