



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6 /DFS/MS/School/NDZ/2024/ 247

Dated: 16/05/2024

To,

The Manager,
Shri R.B. Public School,
E - 135, Dilshad Garden,
Delhi - 110095.

Sub: - Regarding grant of Fire Safety Certificate in r/o Shri R.B. Public School located at E - 135, Dilshad Garden, Delhi - 110095.

Sir,

This has a reference to your outdoor dairy no.731 dated 16/04/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 07/05/2024 in the presence of Mr. Deepak Sharma (Manager) and observed that building comprised of ground plus two upper floors only.

Following shortcomings were observed during time of inspection:

1. The staircase of width 1.10 meter is provided instead of required width of 1.50 meter.
2. Fire Extinguishers not provided.
3. First-Aid-Hose Reel provided but not functionable.
4. Fire pump provided but not functionable.
5. Overhead tank of 2,000 liters capacity is provided against the requirement of 10,000 liters
6. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Manager, Shri R.B. Public School located at E - 135, Dilshad Garden, Delhi - 110095.