

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/BP/2024/ 249

Dated: 09 05 2024

To,

The Executive Engineer (Other Project Division-I), PWD, Rouse Avenue Court Complex, DDU Marg, New Delhi-110002

Sub:- Rejection of building plans from fire safety point of view in r/o Construction of District Court Complex at Sector-26, Rohini, Delhi.

Sir,

With reference to online application No. PWD/Fire/2024/04/5/276 dated 22.04.2024 on the subject cited above, it is informed that the online building plans in respect of District Court Complex at Sector-26, Rohini, Delhi were scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcoming were observed:-

- There is difference in information w.r.t. occupancy, travel distance from the dead end, Fire Tower, Compartmentation etc. provided in CAF and the building plans submitted.
- 09 meter wide road along with 12 m turning radius for fire tender movement are not proposed as per clause 8.2 of UBBL-2016.
- 3. Refuge area is not proposed as per clause 9.3.6/ 9.3.7 of UBBL-2016.
- 4. Fire Towers are not proposed as per clause 9.3.13/1.4.46 of UBBL-2016.
- 5. The exit shall not pass through occupied area as per UBBL-2016/NBC-2016, Part-IV.
- Compartmentation is not proposed as per clause 8.4.6 of UBBL-2016/ NBC-2016, Part-IV.
- First floor of block-A staircases for parking area are not proposed as per UBBL-2016/NBC-2016, Part-IV.
- 8. Lifts are not proposed as per UBBL-2016/NBC-2016, Part-IV.
- Width & number of doors are not proposed as per requirement of occupancies like in assembly areas, institutional areas etc. as per UBBL-2016/NBC-2016, Part-IV.
- 10. DG room, HVAC Room, Transformer, Electrical Room/ Shafts etc. are not protected with fire check doors of 02 hour fire rating resistance as per UBBL-2016/NBC-2016, Part-IV.
- 11. Glass of lift lobby is not proposed with fire rated glass of 02 hour fire rating resistance as per UBBL-2016/NBC-2016, Part-IV.

In view of the above, the building plans are rejected with a request to resubmit plans after rectification of above shortcoming for further consideration in the matter.

Yours faithfully,

Director