



75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/2024/SZ/ 289

Dated: 27/05/2024

To

Sh. Santosh Kumar, Addl. GM (Engg.),  
NBCC (India) Limited,  
GPRA Complex, New Moti Bagh,  
New Delhi-110023

**Sub: Regarding renewal of Fire Safety Certificate in r/o Single Basement Parking at  
GPRA Complex, New Moti Bagh, New Delhi-110023**

Sir,

This has reference to your letter No. NBCC/CGM/NMB/DFS/2024/63 dated 08/04/2024 received through outdoor diary No. 367 dated 08/04/2024, on the subject cited above. In this connection, the said premises was inspected by the officer concerned of this department on 15/05/2024 to verify the compliance of shortcomings observed & communicated by this department vide letter No. F.6/DFS/MS/2024/SZ/284 dated 16/02/2024 in the presence of Sh. Basu Dev Shukla (Ex-AGM) and observed that the following shortcomings has not been complied so far.

1. The smoke management system found provided but non-functional.
2. Automatic sprinkler system found non-functional.
3. The fire pumps were not on auto mode.

In view of the above, the application for renewal of fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE