

c/95.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024(24)

Dated: 17/05/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o M/s Hotel Star Palace Located at 1st, 2nd & 3rd floor 15A/17, WEA Karol Bagh, New Delhi-110005.

Sir,



Please refer to online application No. 2024032703633, dated 22/04/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 15/05/2024 in the presence of Sh. Jagdish Yadav (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Door closers found removed/ defective at some places.
2. Ventilation shaft found covered by flammable material at all the floors & being used as store.
3. MOEFA found nonfunctional.
4. Basement found locked could not be inspected

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service


Copy to: - The Manager, M/s Hotel Star Palace Located at 1st, 2nd & 3rd floor 15A/17, WEA Karol Bagh, New Delhi-110005.