

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/EH/NDZ/2024/ 287

Dated: 24/ 05 /2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Isthara Parks Pvt. Ltd. located at 1st Floor, Qutab Road, Sadar Bazar, Delhi - 06.

Sir,

This has reference to online application ID No. 2024032003292 dated 25.04.2024 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22.05.2024 in presence of Mr. Suresh and it was observed that building is comprised of 02 Basement + Ground + 04 upper floors (but food court running at 1st floor only). During inspection, following shortcomings were observed:

1. 02 nos. of staircases are provided having width of 1.50 m each against the requirement of 2.0 m & 1.5 m respectively.
2. 02 nos. of doors are provided having width of 1.50 m & 1.32 m respectively against the requirement of 2.0 m & 1.5 m respectively.
3. Overhead water storage tank provided 10,000 liters against the requirement of 20,000 liters.
4. Exit signages are not adequately provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)

Director
Delhi Fire Service o/c
Tel: 01123414000

60
24/5

Copy to:-

The Manager,

M/s Isthara Parks Pvt. Ltd. at 1st Floor, Qutab Road, Sadar Bazar, Delhi - 06.