

C-100

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2024/ 234

Dated: 16/05/2024

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of M/s Naaz Guest House located at  
**734, Kabari Bazar, Jama Masjid, Delhi - 06.**

Sir,

This has reference to online application I.D. no. 2024042205777 dated 22.04.2024 on the subject cited above. In this connection, it is to inform you that guest house was visited by the officer concerned of this department on 08.05.2024 in the presence Mohd. Danish (Owner) and it was observed that building is comprised of Ground + 04 upper floors. During inspection, following shortcomings were observed:

1. Fire check door which are required as per gazette notification dated 27.05.2019, not provided.
2. Fire pump not in auto start mode.
3. Exit signages are not adequately provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

00  
14/5/24

**Copy to:-**

The Manager,  
M/s Naaz Guest House at 734, Kabari Bazar, Jama Masjid, Delhi - 06.