



75
आजादी का
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/Hospital/2024/ 290

Dated: 27/05/2024

cl/29

To,
The Executive Engineer,
Health Maintenance Division,
(South West) M-123, DGER Complex,
Opposite D.P.S., Sector-3, Dwarka,
New Delhi - 110078.

Subject: - **Regarding Issuance of Fire Safety Certificate in R/o New Hospital Block in Acharya Bhikshu Govt. Hospital Located at Moti Nagar, New Delhi- 110027.**

Sir,

Please refer to your Email dated 18/04/2024 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officers concerned of this department on 15/05/2024 in the presence of Sh. Sikander Srivastav to see the functioning of fire safety equipments provided in the building. As per the guideline issued vide this department letter no. F6/DFS/MS/BP/2016/303 dated 25/11/2016.

During inspection it has been observed that the building is comprised of Basements + Ground + 07 Upper Floors Fire Safety arrangements such as Fire Extinguisher, First-Aid Hose Reel, MOEFA, Public Address System, Internal Hydrant, Yard Hydrant, Over Head Tank, etc are provided. However, the following shortcomings were observed:-

1. Fire Check doors are not provided at some places.
2. Smoke management system is provided but not functional.
3. Smoke Detectors are provided but not functional.
4. Exit signages not provided.

In view of above Shortcomings the application for issuance of Fire safety Certificate is cannot consider at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier. Statutory authority may take suitable necessary action as deemed fit.

Yours Faithfully,

(Atul Garg)
Director

Copy To: -

1. The Medical Superintendent, New Hospital Block in Acharya Bhikshu Govt. Hospital Located at Moti Nagar, New Delhi- 110027

cl/29
24/5/2024