

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2024/EH 199

Dated:-71/05/2024

To

The Manager M /S Coffee Day Global Ltd, Shop No. B-28, Inner Circle, Connaught Place, New Delhi.

Sub: Regarding issuance of FSC in r/o M /S Coffee Day Global Ltd, Shop No. B-28, Inner Circle, Connaught Place, New Delhi.

Sir,

This has reference to online ID No. 2024042706303 dated 28.04.24, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 09/05/2024 in the presence of Mr. Nadeem and following shortcomings were observed:-

- 1. Alternate staircase of 1.5m is not provided
- 2. Alternate exit door of 1.5 meter is not provided.
- 3. First aid hose reel and hydrant systems are not provided.
- 4. Terrace pump of 450 LPM is not provided.
- 5. Overhead fire water tank of 20,000liter capacity is not provided.

In view of above, the case is rejected. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,

DIRECTOR Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.