

5/10

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZI/2024/ 246

Dated: 17/05/2024

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of M/s Delhi Muslim Guest House situated at 2274, Gali Qasim Jan, Ballimaran, Delhi - 06.

Sir,

This has reference to online application I.D. no. 2024042606180 dated 26.04.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned from this department on 11.05.2024 in the presence of Manager and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. First aid hose reels provided but not functional.
2. CO detectors provided but not functional.
3. Fire pump not in auto start mode.
4. Exit signages are not adequately provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,

  
(Atul Garg)

Director  
Delhi Fire Service o/c  
Tel: 011-23414000

**Copy to:-**

The Licensee,  
M/s Delhi Muslim Guest House at 2274, Gali Qasim Jan, Ballimaran, Delhi - 06.

SO 17/5  
17/5