



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



489

No. F 6 / DFS / MS / BP / 2024/ 308

Dated: 03 16/2024

To,

The Jt. Director (L&I) Bldg.
DDA, Vikas Sadan,
New Delhi.

Sub: Online Building plans in r/o revised sanction Drawing of Senior Secondary School belonging to Sri Venkateshwar Education Society, Sector-10, Dwarka, New Delhi.

Sir,

Please refer your online file No. DW10/0169/2023 dated 18/05/2024 on the subject cited above. In this connection this is to inform you that the referred online building plans have been examined and observed following shortcomings:

1. Entry to one staircase is not through Fire Check Doors as per clause 7.11 of UBBL-2016.
2. Entry to lift lobby is not through Fire Check Door as per clause 8.4.4 (i) of UBBL-2016.
3. Use of basement is not mentioned.

Therefore, plans are rejected.

Yours faithfully

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

[Handwritten signature]
CS