

(-3)

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI – 110001**

No.F.6/DFS/MS/SZ/2024/ 288

Dated: - 28/05/2024

To,

The Principal,  
Govt. Co-Ed. Sr. Sec. School,  
Pochanpur, Sector-23, New Delhi-110077.

**Subject: Renewal of Fire Safety Certificate in r/o Govt. Co-Ed. Sr. Sec. School, Located at Pochanpur, Sector-23, New Delhi-110077.**

Sir,

Please refer to your letter No. PPS/2024/87 Dated 03/02/2024 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned of this department on 17/05/2024 in the presence of Ms. Keerti Yadav (HOS) from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. Hose reel hose found nonfunctional / damaged.
2. Terrace pump of capacity 450 lpm found nonfunctional.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service

6/c  
28/5/24

Copy to; - Directorate of Education Old Secretariat Delhi – 110054.