

d u

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2024/ EH/182

Dated: 13/05/2024

To

The Manager  
Jain Refreshment Corner Ranisa  
Shop No. P-14-90, Connaught Place,  
New Delhi.

Sub: Regarding issuance of FSC in r/o M /S Jain Refreshment Corner Ranisa, Shop No. P-14-90, Connaught Place, New Delhi.

Sir,

This has reference to online id no. 2024041304962 dated 13/04/24, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 30/04/24 in the presence of Manager and following shortcomings were observed:-

1. Hose reel, hydrant and pumps found nonfunctional.
2. Further, FSC was earlier issued only for ground floor whereas you have applied mezzanine floor also. Accordingly, correction is required in application form also.

In view of above, the case is rejected. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.