



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2024/ 297

Dated: 28/05/2024

To

The Principal,  
M.C. Primary School,  
Kirti Nagar (Ind. Area),  
New Delhi -110015.

**Subject: Regarding issuance of Fire safety Certificate in respect of M/s. M.C. Primary School, Kirti Nagar Ind. Area, New Delhi – 110015.**

Sir,

Please refer to your letter dated 26/04/2024 received through outdoor diary no. 1248 dated 01/05/2024 on the subject cited above. In this connection, it is to inform you that the said building was re inspected by the officer concerned of this department on 15/05/2024 in presence of Smt. Sangeeta Sawlani (Incharge) to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/School/WZ/2023/389 dated 11/09/2023.

However the Status of the Shortcomings is as under.

S. no.	Shortcomings	Status
1.	01 Staircase is provided having width 1.20 m. If one staircase is less then 1.5m then alternate staircase is not less than 0.75m.	Rectified
2.	First Aid Hose reels are provided but not functional.	Not Rectified
3.	Terrace fire pump of 450 lpm is provided but not functional.	Not Rectified

In addition to above following short coming were observed.

1. Overhead tank capacity of 10,000 ltr is found removed.

In view of above shortcomings the application for issuance of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

  
(Atul Garg)  
Director

Copy To: -

1. The Director, Directorate of Education, Old Secretariat, New Delhi.

1/2  
21/5/2024