



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 294

Dated: 28/05/2024

To

Sh. P.D. Kabeer (Ex. Engg., Elect)
Civil Line Zone, Municipal Corporation of Dehi.,
16, Rajpura Road, New Delhi-110054.

Sub: -Regarding issuance of fire safety certificate in r/oMCD Primary School located at Janta Vihar, Mukundpur, Delhi-110042.

Sir,

Please refer to your letter No. EE(E)/CLZ/2024-25/D-88 dated 26.04.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 15.05.2024 to verify the fire safety measures issued vide NBC Pat-IV and observed that the building was comprised of ground & 02 upper floors only. At the time of inspection Sh. Shyam Lal Yadav was also present at site. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. There is 03 nos. of staircases provided width of 02 nos. of 1.50m & 01 no. of 1.25m only one staircase continues from ground to terrace level against the requirement of 03 nos. of staircase continues from ground to terrace level in case of any emergency.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

21/5