

C-35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/School/SZ/2024/ 290

Dated 28/05/2024

To,

The Principal,
M.C.D. Primary School,
Lajwanti Garden, New Delhi- 110046.

Sub: - Regarding renewal of fire safety certificate in r/o M.C.D. Primary School located at Lajwanti Garden, New Delhi- 110046.

Sir,

Please refer to your letter Form "J" received in this office outdoor diary No. 1537 dated 09.05.2024, on the subject cited above. In this connection, it is to inform you that the above said school building was inspected by the officer concerned of this department from safety point of view on dated 20.05.2024 in presence of Mr. Vijay Pal Pilwal (Principal).

During the course of inspection found that the school building comprised of ground plus three upper floors. However, the following shortcomings have been observed: -

- 1 First Aid hose reels found provided but not functional.
- 2 Terrace Fire pump Capacity of 450 LPM found provided but not functional.
- 3 Exit signage found removed.

Keeping in view of above, issuance of fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

The Director of Education, GNCT of NCT of Delhi, Old Secretariat- 110054.

[Handwritten signature]