

C-6



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 293

Dated: 28/05/2024

To

The Principal
New Era Public School at Kh. No- 101/17,
West Kamal Vihar, Kamalpur, Burari, Delhi-84.

Sub: - Regarding grant of fire safety certificate in r/o New Era Public School located at Khasra No- 101/17, West Kamal Vihar, Kamalpur, Burari, Delhi-110084.

Sir,

Please refer to your letter received through online e-mail dated 11.05.2024 on the subject cited above. In this connection this is to inform you that the above mentioned school building was inspected by the officer concerned of this department on 15.05.2024 in the presence of Sh. Ritesh Gosain (Manager) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the school building is comprised of ground floor only. The observations/ shortcomings made are as under:-

1. The main gate of school entry width of 2.60m is provided against the requirement of 4.50m.
2. The class rooms all door size is provided 90cm against the requirement of 01m.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

21/5