

5

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

NO. F6/DFS/MS/SZ/2024/189

DATED: 16/05/2024

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

Subject: - Issuance of Fire safety Certificate in r/o Om corner Located at Ground Floor Plot No. 5050-1, Sant Nagar, New Delhi – 110005.

Sir,


Please refer to online application No. 2024041705367, dated 22/04/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 11/05/2024 in the presence of Sh. Umesh from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Hose reel hose & hydrants found not provided.
2. MOEFA & PA found not provided.
3. Terrace pump of capacity 450 lpm found not provided.
4. Overhead fire water tank of capacity 20000 ltr found not provided.
5. Exit Signage found not provided.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter

Yours faithfully,


(Atul Garg)
Director,
Delhi Fire Service

Copy to:-

1. The Manager, Om corner Ground Floor Plot No. 5050-1, Sant Nagar, New Delhi – 110005.