



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

75
आजादी का
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/BP/2024/ 293

Dated: 29 /05/2024

To,

The Executive Engineer -I (Bldg.)HQ,
Municipal Corporation of Delhi,
9th Floor, Civic Centre, Minto Road,
New Delhi – 110002.

Sub: Online building plan in r/o Plot No. 3, Block-E, Rewari Line, Industrial Area, Phase-II, Mayapuri, New Delhi - 110064.

Sir,

Please refer your Request ID No. 10118685 dated 22-05-2024 on the subject cited above. In this connection it is to inform you that the online building plans have been examined by this department and observed following shortcomings:

1. The Industrial occupancy has been mentioned in CAF, whereas, the plans are showing majorly Storage Occupancy.
2. Floor plan of basement is not matching with the section.
3. Entry to one staircase in basement is not through Fire Check Door.
4. Width of F.C.D. is not marked on the plan.

Therefore, plans are rejected.

Yours faithfully

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

[Handwritten signature]
03