

c/05

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/EH/NDZ/2024/ 200

Dated: 21/05/2024

To

The Joint Commissioner of Police (Lic.),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: - Regarding issuance of Fire Safety Certificate in respect of M/s Pushpa Food And Services situated at Metro Food Plaza, Ground Floor, Metro Gate No. 3, Delhi - 110006.

Sir,

This has a reference to online application ID No. 2024041905562 dated 20.04.2024 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.05.2024 in presence of Mr. Bhupender and it was observed that building is comprised of Ground + 01 upper floor **but restaurant is running at ground floor only**. During inspection, following shortcomings were observed:

1. 02 nos. of doors are provided having width of 1.50 m & 1.32 m respectively against the requirement of 1.5 m each.
2. First aid hose reel not provided.
3. MOEFA not provided.
4. Internal hydrant system (down comer) not provided.
5. Fire pump of capacity 450 LPM not provided.
6. Over head water storage tank of 20,000 liters capacity is required exclusively for firefighting.
7. Exit signages are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director o/c
Delhi Fire Service
Tel: 01123414000

Copy to:-

The Manager,
M/s Pushpa Food And Services at Metro Food Plaza, Ground Floor, Metro Gate No. 3, Delhi- 110006.