

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F.6/DFS/MS/NDZ/2024/299

Dated: 31 .05.2024

To,

Dr. S. Venkataratnam  
General Secretary  
Plot no. 1 DDU Marg , New Delhi.

**Subject:- Regarding renewal of Fire Safety Certificate in r/o Rashtriya Seva Samithi –located at plot No 01 , DDU Marg, New Delhi .**

Sir,

This has a reference to your letter no. nil dated 30.04.2024 on the subject cited above. The site was visited by officers concerned of this department in the presence of Smt. Rajshri, Manager on dated 21.05.2024. During inspection following shortcomings have been observed.

1. Fire check door found removed at main staircase and lift lobby at some place.
2. Diesel engine pump found nonfunctional.

In view of above, the FSC cannot be renewed . Further, the occupancy of building /premises in absence of valid fire safety certificate shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully,

  
(Atul Garg )  
DIRECTOR  
Delhi Fire Service

Copy to :

1. The Commissioner, MCD, Civic Centre , New Delhi.