

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/17

No. F.6/DFS/MS/EH/NDZ/2024/195

Dated: 16/05/2024

To

The Joint Commissioner of Police (Lic.),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: - Regarding issuance of Fire Safety Certificate in respect of M/S Sagar Ratna Restaurant Pvt. Ltd. at Shop No. 13, Alipur Road, Civil Lines, Delhi 110054.

Sir,

This has a reference to online application ID No. 2024040604347 dated 10.04.2024 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the team of officers concerned of this department on 10.05.2024 in presence of Mr. P. Tomar (Care Taker) and it was observed that the shortcomings issued vide letter no. F.6/DFS/MS/EH/NDZ/2023/666 dated 13.12.2023 have been partially complied except following which still exists:-

1. 02 number of staircase having width 1.50 mtr. must be provided, hence additional staircase having width of 1.5 mtr. is required to be provided.
2. Fire pump not in auto start mode.
3. Exit signages are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

faithfully,

Yours


(Atul Garg)
Director
Delhi Fire Service
Tel: 0112341400
OK
15/5

Copy to:-

The Manager,
Sagar Ratna Restaurant Pvt. Ltd. at Shop No. 13, Alipur Road, Civil Lines, Delhi 110054.