



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

NO. F6/DFS/MS/CGHS/SZ/2024/ 304

DATED: 03/06/2024

To,

The President,
Sarve Satyam CGHS Ltd.
Plot No 12, Sector 04, Dwarka, New Delhi.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Sarve Satyam CGHS Ltd. Located at Plot No 12, Sector 04, Dwarka, New Delhi.

Sir,

This is in reference to your letter No. SS001/DFS dated 29/04/2024 on the subject cited above. In this connection it is to inform to you that the above said premises was inspected by the officer concerned of this department on 28/05/2024 in the presence of Sh. Narender Singh Negi (Manager) from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. The internal road around the building found encroached. The trimming of trees is required to done for free movement of fire vehicle in case of fire emergency.
2. Hose reel hose and hydrants found nonfunctional.
3. Coupling/hoses found missing at some places
4. MOEFA & PA system found nonfunctional.
5. Fire pumps at terrace level found nonfunctional & main valves found closed.
6. Fire pumps at ground level not seen during the visit.
7. Terrace found locked. The terrace must be kept free from lock & key.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter. The occupancy of the building premises without valid Fire Safety Certificate is on the risk and responsibility of the management committee

Yours faithfully,

(Atul Gang)
(Director)

Delhi Fire Service

Copy to:-

The Joint Director (Building), DDA, Vikas Sadan, INA, New Delhi.