



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-16



No. F6/DFS/MS/WZ/2024/ 273
To,

Dated: 28/05/2024

The Principal,
Sarvodaya Kanya Vidyalaya,
Tulsi Nagar, Delhi-110034.

Sub: - Inspection report in r/o Sarvodaya Kanya Vidyalaya, Tulsi Nagar, Delhi- 110034.

Sir,

This is in reference to your e-mail id dated 08/05/2024 on the subject cited above. In this connection, it is to inform you that the above said school building was re-inspected by the officer concerned of this department on 22/05/2024 in the presence of Dr. Rakesh Kumar Jaiswal (Principal) to verify the compliance of shortcomings communicated vide this department letter No. F6/DFS/MS/School/2024/WZ/46 dated 08/02/2024.

The status of shortcoming is as under:-

Sr. No	Shortcomings	Status
1.	First aid hose reel provided but not functional.	Not Rectified
2.	Terrace level pump found provided but not functional.	Not Rectified
3.	Exit signage's not provided.	Rectified
4.	Electric wiring should be in metal conduit/ concealed type.	Rectified

In view of the above shortcomings, the request for issuance of Fire Safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for further necessary action in this regard.

Yours faithfully,

(A.P. Garg)

Director

Ph. 011-23414000

[Handwritten signature]
26/5

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.