



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5/24
आपत्ती का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024/ 286

Dated: 28/05/2024

To

The Principal,
Satyanam Public School,
L-1, Sangam Vihar, New Delhi-80.

Sub: Regarding renewal of Fire Safety Certificate in respect of **Satyanam Public School** located at **L-1, Sangam Vihar, New Delhi-80.**

Sir,

With reference to the letter bearing outdoor diary no. 14210 dated 14.03.2024 on the subject cited above, it is informed that the said building was inspected by the officer concerned of this department on 17.05.2024 in the presence of Mr. Naresh Kumar (Treasurer) and it was observed that school building is comprised of Basement + Ground + 02 upper floors. During the inspection following shortcoming were observed:-

1. Hose reel found not functional
2. Fire pump found not functional.
3. Terrace water tank of 15,000 liters found not provided (exclusively for firefighting).
4. Exit sinages found removed.

In view of above shortcomings, the application renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

28/05/24 W

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.