

20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 2024/ 295

Dated:-28/05/2024

To,
The Head Of School,
M/S S.K.V, Sarai Rohilla,
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S S.K.V, Sarai Rohilla, New Delhi.

Sir,

This has reference to letter no SKV/SR/2024/497 dated 09/04/24, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 08.05.24 in the presence of Smt. Arpana and following shortcomings were observed.

1. Hose reel & hydrant system found non functional.
2. Pump found non functional.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.