



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/Audi/2024/SZ/ 278

Dated: 28/05/2024

To

Sh. V.K. Mathwal (Principal),  
PM Shri Kendriya Vidyalaya No-2,  
Delhi Cantt, APS Colony,  
Gurugram Road, New Delhi-110010

**Sub: Regarding renewal of fire safety certificate in r/o S.R. KVS Auditorium Building at  
PM Shri K V No-2 Delhi Cantt. New Delhi-110010**

Sir,

This has reference to your letter No. F.N.Audi/PM\_SHRI/KVNO.2/DC/2023-24/47 dated 23/03/2024, received through outdoor diary No. 358 dated 08/04/2024. In this connection, the said premises was visited by the officer concerned of this department on 17/05/2024 in the presence of Sh. Prem Singh Sekhawat (Vice Principal), verify the status of the fire safety arrangements provided therein. During the inspection, the shortcomings observed are as below.

1. Staircases found obstructed by waste material/furniture.
2. Electrical shaft found un-sealed.
3. Hose-reel found provided but non-functional/nozzle missing.
4. Detectors found provided but non-functional.
5. One of the internal hydrants at ground floor found non-functional/opening lever missing.
6. The terrace level pump was not on auto mode.

In view of the above, the application for renewal of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE  
AK 80

Copy to: -

1. The Joint Commissioner of Police, (Lic), 1<sup>st</sup> Floor, Police Station Defence Colony, New Delhi-110049
2. The Asst. Commissioner, Kendriya Vidyalaya Sangathan, Delhi Region, JNU Campus, New Mehrauli Road, New Delhi-110067