



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 300

Dated: 28/05/2024

To

Sh. Mihir Kr. Chaudhary (Manager),
Star Public School at Ajeet Vihar,
Burari, Delhi-110084.

Sub: - Regarding issuance of fire safety certificate in r/o Star Public School located at Ajeet Vihar, Burari, Delhi-110084.


Sir,

Please refer to your letter received through online e-mail dated 11.05.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 15.05.2024 to verify the fire safety measures issued vide NBC Pat-IV and observed that the building was comprised of ground & 02 upper floors only. At the time of inspection Sh. Mihir, Kr. Chaudhary (Manager) was also present at site. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. There is only 01 staircase width of 1.20m provided ground to terrace level against the requirement of 02 nos. staircase width of 1.50m each from ground to terrace level.
2. The width of class room doors is 01m against the requirement of 1.20m
3. First aid hose reel hose is not provided.
4. MOEFA system is not provided.
5. Terrace level fire pump capacity of 450lpm is not provided.
6. Terrace level fire fighting water tank capacity of 10,000ltr is not provided.
7. Exit signage and floor signage not provided at strategic locations in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully


(Anil Garg)
Director
Ph:-011-23414000
20/5/24

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.