



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7  
आप्लादीक  
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024/ 276

Dated: 28/05/2024

To

The Principal,  
Sun Rise Public School,  
Tughlakabad Village, New Delhi-44.

**Sub:-** Regarding issuance of Fire Safety Certificate in r/o Sun Rise Public School located at Tughlakabad Village, New Delhi-44..

Sir,

With reference to letter bearing outdoor diary no. 1428 dated 06.05.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 17.05.2024 in the presence of Mrs. Kalpana (Incharge) and it was observed that the building is comprised of Ground + 2 upper floors. During the inspection following shortcomings were observed:-

1. The school is not accessible to fire engines as approach road width is less than 6.0 meters.
2. 2 nos. of staircases 1.50 meters each not provided in the building.
3. First aid hose reels found not provided.
4. Fire pump having capacity 450 LPM with 40 m head found not provided.
5. Terrace water tank of 10,000 liters found not provided (exclusively for firefighting).
6. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

28/5/24

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.