

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/BNQT/2024/SZ/69

Dated: 20/05/2024

To

The Addl. Commissioner of Police,
Lic Branch, 1st Floor, PS Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of Fire Safety Certificate in r/o **M/s Ten** (A Unit of JPS Catering Pvt. Ltd.) B-10, DDA Community Centre, Triveni Complex, Saikh Sarai, New Delhi-110016

Sir,

This is in reference to with **MHA Portal ID 2024041905587 dated 19/04/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.05.2024 in the presence of Ms. Pushpi (Manger) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Smoke management system provided but found non-functional.
2. MOEFA not working.
3. Some of sprinklers are covered under the false ceiling which needs to be extended.
4. Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

