



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

11/10

No.F6/DFS/MS/School/SZ/2024/ 274

Dated: 28/05/2024

To

The Principal,
Wings Academy School,
Near Arya Samaj Mandir, Bhangar Mohalla,
Tughlakabad Village, New Delhi-44.

Sub: Regarding renewal of Fire Safety Certificate in respect of **Wings Academy School** located at **Near Arya Samaj Mandir, Bhangar Mohalla, Tughlakabad Village, New Delhi-44.**

Sir,

This has reference to letter bearing outdoor diary no. 14639 dated 27.03.2024 on the subject cited above. In this context it is informed that the said building was inspected by the officer concerned of this department on 17.05.2024 in the presence of Mrs. Tabassum (Principal) and it was observed that previously school running on ground floor only of the building which is comprised of Ground + 01 upper floor now the school running at Ground + 1 upper floor . During the inspection following shortcoming were observed:-

1. Alternate staircase having width not less than 0.75 meter is required.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Gang)

Director

Delhi Fire Service

28/5/24

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.