

550

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/ 265

Dated: 24/05/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Al-Shahansha Guest House situated at 5190, Ballimaran, Chandni Chowk, Delhi-06.

Sir,

This is in reference to online application I.D. no.2024050606950 dated 06.05.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned of this department on 18.05.2024 in the presence Mr. Afaq (Manager). During inspection, following shortcomings were observed:-

1. Smoke management system required as per Gazette Notification 27.09.2019, not provided.
2. Fire extinguishers found non functional and due for refilling.
3. Hose reel hose non functional and nozzle found removed at 1st floor.
4. CO detectors and hooters provided but found non functional.
5. Public address system not provided.
6. Fire pump of 450 lpm capacity and 40 meter head not provided.
7. Exit signages not adequately provided.
8. Alternate source of power supply not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

Copy to:-

The Licensee,

M/s Al-Shahansha Guest House, 5190, Ballimaran, Chandni Chowk, Delhi-06.