GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI **HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/SZ/2024/ 203

Dated 22/05/2029

To,

The Joint C.P. (LIC.), 1st floor, Police Station, Defense Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s. M/s. Ariya Decor Pvt. Ltd. Located at J-2/6, Third floor, Dutt Market, Rajouri Garden, New Delhi- 110027. Sir,

Please refer to online application ID 2024041004633 dated 01.05.2024, on the subject cited above. In this connection, it is to inform you that the above said eating house running at third floor of a building comprised of basement, ground plus three upper floors. The above said assembly building (Restaurant) was inspected by the officer concerned of this department from safety point of view on dated 09.05.2024 in presence of Sh. Abhishek Khemka (Owner).

During the course of inspection, the following shortcomings have been observed: -

- 1 Two staircases having width of 1.20 & 1.50 m found provided against requirement of two staircase with width of 1.50 m each.
- 2 Two exits door width of 1.20 m each found provided against requirement of two exit doors
- 3 Fire Check Doors are not provided in kitchen.
- 4 First Aid hose reel/hydrant found provided but not functional.
- Smoke Detector found not provided.
- MOEFA found not provided.
- 7 Fire pumps are not provided.
- 8 Underground water storage tank capacity of 1,00,000 ltrs and overhead water storage tank capacity of 10,000 ltrs found not provided.

9 Exit signage & Lift signage are not provided at the places mentioned during the inspection.

Keeping in view of above, issuance of fire safety certificate cannot be considered at this stage. Restaurant management may be requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department.

Yours faithfully

Director

Copy to-

1. The Owner/Occupier, M/s. Ariya Decor Pvt. Ltd., J-2/6, Third floor, B.K. Dutt Market, Rajouri