

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2024/ 205

Dated:-24.05..2024

To

The Manager
M /S Coffee Day Global Ltd,
Shop No. 49, Block 205 C,
Bangali Market Plot no. 7, New Delhi.

Sub: Regarding issuance of FSC in r/o M /S Coffee Day Global Ltd, Shop No. 49, Block 205 C, Bangali Market Plot no. 7, New Delhi.

Sir,

This has reference to online ID No. 2024042706300 dated 27.04.24, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 15/05/2024 in the presence of Mr. Vikas and following shortcomings were observed:-

1. 02 exits of 1.5 meter are not provided.
2. First aid hose reel and hydrant system are not provided.
3. Fire Extinguishers are not provided as per IS 2190.
4. MOEEFA system not provided.
5. Terrace pump of 450 LPM is not provided.
6. Overhead fire water tank of 20,000 liter capacity is not provided.

In view of above, the case is rejected. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,


(Ajul Garg)
DIRECTOR
Delhi Fire Service


Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.