

c/62

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2024/GH/273

Dated: 27.05/2024

To

The Manager
M/S D Suites Guest House,
3311-14, Gali Hari Mandir,
Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o D Suites Guest House, 3311-14, Gali Hari Mandir,
Pahar Ganj, New Delhi.

Sir,

This has reference to online ID No. 2024033103912 dated 19/04/24, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 14/05/24 in the presence of Manager and observed Smoke management is not provided as per gazette notification dated 27.05.2019.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station,