

C-16

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2024/ 263

Dated: 24/05/2024

To

The Joint Commissioner of Police,  
Licensing Unit 1st Floor,  
P.S Defence Colony,  
New Delhi-110049

**Subject: - Renewal of Fire Safety Certificate in respect of M/s Guest House South Indian, Located at 1<sup>st</sup>, 2<sup>nd</sup>, & 3<sup>rd</sup> floor 10211-16, Padam Singh Road, Karol Bagh, New Delhi - 110005.**

Sir,

Please refer to online application No. 2024042205779, dated 22/04/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 18/05/2024 in the presence of Sh. Mohan (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. One staircase in basement found locked/ blocked.
2. Fire Check Doors found not provided in one staircase.
3. Smoke exhaust system found nonfunctional/inadequate.
4. Sprinkler system in basement found partially removed.
5. Exit signage found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: - The Manager, M/s Guest House South Indian, Located at 1<sup>st</sup>, 2<sup>nd</sup>, & 3<sup>rd</sup> floor 10211-16, Padam Singh Road, Karol Bagh, New Delhi - 110005.