



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

c-32



No. F-6/DFS/MS/EH/WZ/2024/ 206

Dated:- 27/05/2024

To,

Smt. Urmil Kakkar,
M/s. Invitation Restaurant,
Plot No. 3, Local Shopping Centre
Near SBI Bank, Ashok Vihar, Ph. II,
Delhi- 110052.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Invitation Restaurant, Plot No. 3
Local Shopping Centre, Near SBI Bank, Ashok Vihar, Phase- II, Delhi- 110052.

Sir,

Please refer to MHA application ID 2024042405985 dated 28.04.2024 on the subject cited above. Above said eating house is running at ground and mezzanine floor in a building comprised of basement, ground, mezzanine plus three upper floors. In this connection it is to inform you that the above said assembly building (Restaurant) was inspected by the officer concerned of this department on 21.05.2024 in presence of Mr. Tarun to check the fire safety measures provided in the building.

During the course of inspection it has been observed that fire safety arrangements such as fire extinguishers, first aid hose reels found provided, However the following shortcomings have been observed:-

- 1 Width of staircase found 1.50 m & 1.40 m against the required width of 1.50 m each.
- 2 Basement floor is not compartmentalized/ segregated providing fire check door.
- 3 Internal hydrant not provided.
- 4 Exit signage's not provided.

In View of the above, the application for issuance of Fire Safety Certificate is not considered at this stage and rejected. You are requested to re-apply on MHA portal as and when site is ready for inspection.

Yours faithfully/

(Arul Garg)
Director

Ph: 011-23414000

Copy to:-

1. The Joint Commissioner of Police, Licensing Unit, 1st Floor, Police Station, Defence Colony, New Delhi- 110049.
2. MHA Portal ID No. 2024042405985.

Arul Garg
27/5