

c/77

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/GH/2024/ 201

Dated:- 22/05/2024

To,

The Manager,
M/S Lazeez Affaire (A Unit of Wolfgang Team Hospitality LLP),
K-12, Outer Circle, Connaught Place, New Delhi.

Sub: Regarding grant of FSC in r/o M/s Lazeez Affaire (A Unit of Wolfgang Team Hospitality LLP), K-12, Outer Circle, Connaught Place, New Delhi.

Sir,

This has reference to ID No 2024042305856 dated 23/04/2024, on the subject cited above, it is to inform you that the site was inspected by the officer concerned of this department on 15/05/2024 in the presence of Mr. Tyagi and the following shortcomings were observed:-

1. Hose reel & Pumps found nonfunctional & also not in auto start provision .
2. PA System found nonfunctional.

In view of above, the case is rejected and Fire Safety Certificate (FSC) cannot be issued. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service
o/c

Copy to:-

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station,
New Delhi.