

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/2024/SZ/College/107

Dated: 29/05/2024

To  
Acting Registrar, South Asian University,  
Rajpur Road, Maidan Garhi  
New Delhi 110068

Sub: Regarding issuance of FSC in r/o Faculty of life Science & Biotechnology & Facility of Earth Science (Academic) Building No 3 at South Asian University Complex, Maidan Garhi, New Delhi-110068.

Sir,

This has reference to your letter no SAU/9A-150/2023/289 dated 08/05/2024, received through outdoor diary no 1548 dated 09/05/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 22.05.2024 in the presence of Mr. Deelip Thareja to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Automatic Fire Detection & alarming System provided but found nonfunctional.
2. Pressurization of lift well is not on auto mode.
3. Smoke management system is not on auto mode.
4. MOEFA provided but found nonfunctional.
5. Fire fighting pumps not on auto mode

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

*Am*